

AUTOSAR MCAL R4.0.3 User's Manual

DIO Driver Component Ver.1.0.10 Embedded User's Manual

Target Device: RH850/P1x

All information contained in these materials, including products and product specifications, represents information on the product at the time of publication and is subject to change by Renesas Electronics Corp. without notice. Please review the latest information published by Renesas Electronics Corp. through various means, including the Renesas Electronics Corp. website (http://www.renesas.com).

Renesas Electronics

www.renesas.com

Rev 1.01 Feb 2017

Notice

- Descriptions of circuits, software and other related information in this document are provided only to illustrate the operation of
 semiconductor products and application examples. You are fully responsible for the incorporation or any other use of the circuits,
 software, and information in the design of your product or system. Renesas Electronics disclaims any and all liability for any losses and
 damages incurred by you or third parties arising from the use of these circuits, software, or information.
- 2. Renesas Electronics hereby expressly disclaims any warranties against and liability for infringement or any other disputes involving patents, copyrights, or other intellectual property rights of third parties, by or arising from the use of Renesas Electronics products or technical information described in this document, including but not limited to, the product data, drawing, chart, program, algorithm, application examples.
- 3. No license, express, implied or otherwise, is granted hereby under any patents, copyrights or other intellectual property rights of Renesas Electronics or others.
- 4. You shall not alter, modify, copy, or otherwise misappropriate any Renesas Electronics product, whether in whole or in part. Renesas Electronics disclaims any and all liability for any losses or damages incurred by you or third parties arising from such alteration, modification, copy or otherwise misappropriation of Renesas Electronics products.
- 5. Renesas Electronics products are classified according to the following two quality grades: "Standard" and "High Quality". The intended applications for each Renesas Electronics product depends on the product's quality grade, as indicated below.
 - "Standard": Computers; office equipment; communications equipment; test and measurement equipment; audio and visual equipment; home electronic appliances; machine tools; personal electronic equipment; and industrial robots etc.
 - "High Quality": Transportation equipment (automobiles, trains, ships, etc.); traffic control (traffic lights); large-scale communication equipment; key financial terminal systems; safety control equipment; etc.

Renesas Electronics products are neither intended nor authorized for use in products or systems that may pose a direct threat to human life or bodily injury (artificial life support devices or systems, surgical implantations etc.), or may cause serious property damages (space and undersea repeaters; nuclear power control systems; aircraft control systems; key plant systems; military equipment; etc.). Renesas Electronics disclaims any and all liability for any damages or losses incurred by you or third parties arising from the use of any Renesas Electronics product for which the product is not intended by Renesas Electronics.

- 6. When using the Renesas Electronics products, refer to the latest product information (data sheets, user's manuals, application notes, "General Notes for Handling and Using Semiconductor Devices" in the reliability handbook, etc.), and ensure that usage conditions are within the ranges specified by Renesas Electronics with respect to maximum ratings, operating power supply voltage range, heat radiation characteristics, installation, etc. Renesas Electronics disclaims any and all liability for any malfunctions or failure or accident arising out of the use of Renesas Electronics products beyond such specified ranges.
- 7. Although Renesas Electronics endeavors to improve the quality and reliability of Renesas Electronics products, semiconductor products have specific characteristics such as the occurrence of failure at a certain rate and malfunctions under certain use conditions. Further, Renesas Electronics products are not subject to radiation resistance design. Please ensure to implement safety measures to guard them against the possibility of bodily injury, injury or damage caused by fire, and social damage in the event of failure or malfunction of Renesas Electronics products, such as safety design for hardware and software including but not limited to redundancy, fire control and malfunction prevention, appropriate treatment for aging degradation or any other appropriate measures by your own responsibility as warranty for your products/system. Because the evaluation of microcomputer software alone is very difficult and not practical, please evaluate the safety of the final products or systems manufactured by you.
- 8. Please contact a Renesas Electronics sales office for details as to environmental matters such as the environmental compatibility of each Renesas Electronics product. Please investigate applicable laws and regulations that regulate the inclusion or use of controlled substances, including without limitation, the EU RoHS Directive carefully and sufficiently and use Renesas Electronics products in compliance with all these applicable laws and regulations. Renesas Electronics disclaims any and all liability for damages or losses occurring as a result of your noncompliance with applicable laws and regulations.
- 9. Renesas Electronics products and technologies shall not be used for or incorporated into any products or systems whose manufacture, use, or sale is prohibited under any applicable domestic or foreign laws or regulations. You shall not use Renesas Electronics products or technologies for (1) any purpose relating to the development, design, manufacture, use, stockpiling, etc., of weapons of mass destruction, such as nuclear weapons, chemical weapons, or biological weapons, or missiles (including unmanned aerial vehicles (UAVs)) for delivering such weapons, (2) any purpose relating to the development, design, manufacture, or use of conventional weapons, or (3) any other purpose of disturbing international peace and security, and you shall not sell, export, lease, transfer, or release Renesas Electronics products or technologies to any third party whether directly or indirectly with knowledge or reason to know that the third party or any other party will engage in the activities described above. When exporting, selling, transferring, etc., Renesas Electronics products or technologies, you shall comply with any applicable export control laws and regulations promulgated and administered by the governments of the countries asserting jurisdiction over the parties or transactions.
- 10. Please acknowledge and agree that you shall bear all the losses and damages which are incurred from the misuse or violation of the terms and conditions described in this document, including this notice, and hold Renesas Electronics harmless, if such misuse or violation results from your resale or making Renesas Electronics products available any third party.
- 11. This document shall not be reprinted, reproduced or duplicated in any form, in whole or in part, without prior written consent of Renesas Electronics.
- 12. Please contact a Renesas Electronics sales office if you have any questions regarding the information contained in this document or Renesas Electronics products.
- (Note 1) "Renesas Electronics" as used in this document means Renesas Electronics Corporation and also includes its majority-owned subsidiaries
- (Note 2) "Renesas Electronics product(s)" means any product developed or manufactured by or for Renesas Electronics.

Abbreviations and Acronyms

Abbreviation / Acronym	Description	
ADC	Analog Digital Converter	
ANSI	American National Standards Institute	
API	Application Programming Interface	
ARXML/arxml	AutosaR eXtensible Mark-up Language	
AUTOSAR	AUTomotive Open System ARchitecture	
BSW	Basic SoftWare	
CAN	Controller Area Network	
CCU	Center Control Unit	
DEM/Dem	Diagnostic Event Manager	
DET/Det	Development Error Tracer	
DIO	Digital Input Output	
ECU	Electronic Control Unit	
EEPROM	Electrical Erasable Programmable Read Only Memory	
GNU	GNU's Not Unix	
GPT	General Purpose Timer	
HW	HardWare	
ID/ld	Identifier	
ICU	Input Capture Unit	
I/O	Input/Output	
LIN	Local Interconnect Network	
MCAL	MicroController Abstraction Layer	
MCU	MicroController Unit	
MHz	Mega Hertz	
NA	Not Applicable	
PDF	Parameter Definition File	
PWM	Pulse Width Modulation	
R/W/RW	Read/Write/Read and Write	
RAM/Ram	Random Access Memory	
Rev	Revision	
ROM	Read Only Memory	
RTE/Rte	Run Time Environment	
RUCG	Renesas Unified Code Generator	
SCHM/SchM	Scheduler Manager	
SCI	Serial Communication Interface	
SPI	Serial Peripheral Interface	
SWS	Software Requirements Specification	
WDT	WatchDog Timer	

Definitions

Term	Represented by	
Port	Represents a whole configurable port on a microcontroller device	
Port Pin	Represents a single configurable input or output pin on a microcontroller device.	
SI. No.	Serial Number	

Table of Contents

Chap	oter 1 I	ntroduction	11
1.1.	Docume	ent Overview	13
Chap	oter 2	Reference Documents	15
Chap	oter 3 I	ntegration and Build Process	17
3.1.	DIO Driv	ver Component Makefile	17
	3.1.1.	Folder Structure	17
Chap	oter 4	Forethoughts	19
4.1.	General		19
4.2.	Precond	ditions	19
4.3.	Data Co	nsistency	20
4.4.		on List	
4.5.	User mo	ode and supervisor mode	21
Chap	oter 5	Architecture Details	23
Char	oter 6	Register Details	27
-			
		nteraction between the User and DIO Driver	17
<i>1</i> .1. 3	ervices Pro	ovided by Dio Driver Component to the	Z9
Chap	oter 8	DIO Driver Component Header and Source File	
-		•	31
	-		
Chap	oter 9 (Generation Tool Guide	33
Char	nter 10 /	Application Programming Interface	35
_			
10.1.	•	d Types	
	10.1.1.	Standard TypesOther Module Types	
10.2.			
10.2.	10.2.1.	Dio ChannelType	
	10.2.1.	Dio_PortType	
	10.2.3.	Dio_PortLevelType	
	10.2.4.	Dio_ConfigType	
10.3.	Functio	n Definitions	
	10.3.1.	Dio_Init	37
	10.3.2.	Dio_ReadPort	38
	10.3.3.	Dio_WritePort	38
	10.3.4.	Dio_ReadChannel	
	10.3.5.	Dio_WriteChannel	
	10.3.6.	Dio_ReadChannelGroup	
	10.3.7.	Dio_WriteChannelGroup	
	10.3.8.	Dio_MaskedWritePort	
	10.3.9.	Dio_FlipChannel	
	10.3.10.	Dio_GetVersionInfo	42

Chap	oter 11 I	Development and Production Errors	43
11.1. 11.2.	DIO Driv DIO Driv	ver Component Development Errorsver Component Production Errors	43 44
Chap	oter 12 I	Memory Organization	45
Chap	oter 13 I	P1M Specific Information	47
13.1.	13.1.1.	ion between the User and DIO Driver Translation Header File Parameter Definition File	47
13.2.		ApplicationSample Application Structure	
13.3.	Memory 13.3.1. 13.3.2. 13.3.3.	r and Throughput	51 51 52
Chap	oter 14 i	Release Details	55

List of Figures

Figure 1-1	System Overview of AUTOSAR Architecture	11
Figure 1-2	System Overview of the DIO Driver in AUTOSAR MCAL Layer	12
Figure 5-1	DIO Driver Architecture	
Figure 5-2	DIO Driver Services	24
Figure 12-1	DIO Driver Component Memory Organization	45
Figure 13-1	Overview of DIO Driver Sample Application	48
	List of Tables	
Table 4-1	DIO Driver protected Resources List	20
Table 4-2	Driver Deviation List of DIO module	
Table 4-3	User mode and Supervisor mode details	21
Table 6-1	Register Details	27
Table 8-1	Description of the DIO Driver Component Files	32
Table10-1	DIO Driver Component's API list	
Table11-1	DET Errors of DIO Driver Component	43
Table11-2	DEM Errors of DIO Driver Component	
Table13-1	PDF information for P1M	48
Table13-2	ROM/RAM Details with DET	
Table13-3	ROM/RAM Details without DET	
Table 13-4	Throughput Datails of the APIs	53

Introduction Chapter 1

Chapter 1 Introduction

The purpose of this document is to describe the information related to DIO Driver Component for Renesas P1x microcontrollers.

This document shall be used as reference by the users of DIO Driver Component. The system overview of complete AUTOSAR architecture is shown in the below Figure:




Figure 1-1 System Overview of AUTOSAR Architecture

The DIO Driver is part of the MCAL, the lowest layer of Basic Software in the AUTOSAR environment.

Chapter 1 Introduction

Memory Drivers I/O Drivers Microcontroller Drivers Communication Drivers external Flash Driver internal Flash Driver Watchdog Driver MCU Driver internal EEPROM Drive GPT Driver RAMTest Core SPIHanderDrive FlexRay Driver **PORT Driver** PWM Driver Test CAN Driver ADC Driver DIO Driver LIN Driver ICU Driver ₽ Micro-Ext. BUS EEPRO M FLASH SCI SCI PWM CAN 000 Controller ADC SPI

The Figure in the following page depicts the DIO Driver as part of layered AUTOSAR MCAL Layer:

Figure 1-2 System Overview of the DIO Driver in AUTOSAR MCAL Layer

The DIO Driver Component provides the service for reading and writing to Channels, ChannelGroups and Ports.

The DIO Driver Component comprises of two sections, that is, Embedded Software and the Configuration Tool to achieve scalability and configurability. The DIO Driver Component Code Generation Tool is a command line tool that accepts ECU configuration description file(s) as input and generates source and header file(s) Dio_PBcfg.c and Dio_Cfg.h respectively. The ECU configuration description is an XML file that contains information about the configuration for Port Pins.

Introduction Chapter 1

1.1. Document Overview

The document has been segmented for easy reference. The table below provides the user with an overview of the contents of each section:

Section	Contents
Section 1 (Introduction)	This section provides an introduction and overview of DIO Driver Component.
Section 2 (Reference Documents)	This section lists the documents referred for developing this document.
Section 3 (Integration and Build Process)	This section explains the folder structure, Makefile structure for DIO Driver Component. This section also explains about the Makefile descriptions, Integration of DIO Driver Component with other components, building the DIO Driver Component along with a sample application.
Section 4 (Forethoughts)	This section provides brief information about the DIO Driver Component, the preconditions that should be known to the user before it is used, data consistency details and deviation list.
Section 5 (Architecture Details)	This section describes the layered architectural details of the DIO Driver Component.
Section 6 (Register Details)	This section describes the register details of DIO Driver Component.
Section 7 (Interaction Between User And DIO Driver Component)	This section describes interaction of the DIO Driver Component with the upper layers.
Section 8 (DIO Driver Component Header And Source File Description)	This section provides information about the DIO Driver Component source files. This section also contains the brief note on the tool generated output file.
Section 9 (Generation Tool Guide)	This section provides information on the DIO Driver Component Generation Tool.
Section 10 (Application Programming Interface)	This section explains all the APIs provided by the DIO Driver Component.
Section 11 (Development And Production Errors)	This section lists the DET and DEM errors.
Section 12 (Memory Organization)	This section provides the typical memory organization, which must be met for proper functioning of component.
Section 13 (P1M Specific Information)	This section provides the P1M Specific Information.
Section 14 (Release Details)	This section provides release details with version name and base version.

Chapter 1 Introduction

Reference Documents Chapter 2

Chapter 2 Reference Documents

SI. No.	Title	Version
1.	AUTOSAR_SWS_DIODriver.pdf	2.5.0
2.	r01uh0436ej0130-rh850p1x.pdf	1.30
3.	AUTOSAR_SWS_CompilerAbstraction.pdf	3.2.0
4.	AUTOSAR_SWS_MemoryMapping.pdf	1.4.0
5.	AUTOSAR_SWS_PlatformTypes.pdf	2.5.0
6.	AUTOSAR_BSW_MakefileInterface.pdf	0.3
7.	AUTOSAR BUGZILLA (http://www.autosar.org/bugzilla) Note: AUTOSAR BUGZILLA is a database, which contains concerns raised against information present in AUTOSAR Specifications.	-

Chapter 2 Reference Documents

Chapter 3 Integration and Build Process

In this section the folder structure of the DIO Driver Component is explained. Description of the makefiles along with samples is provided in this section.

Remark The details about the C Source and Header files that are generated by the DIO Driver Generation Tool are mentioned in the "R20UT3709EJ0101-AUTOSAR.pdf".

3.1. DIO Driver Component Makefile

The Makefile provided with the DIO Driver Component consists of the GNU Make compatible script to build the DIO Driver Component in case of any change in the configuration. This can be used in the upper level Makefile (of the application) to link and build the final application executable.

3.1.1. Folder Structure

The files are organized in the following folders:

Remark Trailing slash '\' at the end indicates a folder

X1X\common_platform\modules\dio\src\Dio.c

\Dio_Version.c \Dio_Ram.c

X1X\common_platform\modules\dio\include\Dio.h

\Dio_Debug.h \Dio_PBTypes.h \Dio_Ram.h \Dio_RegWrite.h \Dio_Version.h

X1X\P1x\modules\dio\sample_application\<SubVariant>\make\ghs \App_DIO_P1M_Sample.mak

X1X\P1x\modules\dio\sample_application\ <SubVariant> \obj\<Compiler>

X1X\P1x\modules\dio\generator

\R403_DIO_P1x_BSWMDT.arxml

X1X\common_platform\modules\dio\generator\Dio_X1x.dll

tools\RUCG\RUCG.exe

X1X\P1x\common_family\generator\P1x_translation.h
\Sample_Applications_P1x.trxml
\Global_Application_P1x.trxml

X1X\P1x\modules\dio\user_manual

(User manuals will be available in this folder).

Note: 1. <AUTOSAR_version> should be 4.0.3

- 2. <SubVariant> can be P1M
- 3. <Device_name> can be 701304, 701305, 701310, 701311, 701312, 701313, 701314, 701315, 701318, 701319, 701320, 701321, 701322 and 701323.
- 4. <Compiler> can be ghs

Forethoughts Chapter 4

Chapter 4 Forethoughts

4.1. General

Following information will aid the user to use the DIO Driver Component software efficiently.

- The DIO Driver does not enable or disable the ECU or Microcontroller power supply. The upper layer should handle this operation.
- · Start-up code is not implemented by the DIO Driver.
- DIO Driver does not implement any callback notification functions.
- DIO Driver does not implement any scheduled functions.
- DIO Driver supports the Readback feature.
- The DIO Driver Component is Postbuild time configurable for R4.0.3.
- The file Interrupt_VectorTable.c provided is just a Demo and not all interrupts will be mapped in this file. So the user has to update the Interrupt_VectorTable.c as per his configuration.
- To access the Hardware Registers, The MCAL user should use the Low Level driver Layer. The MCAL user does not write or read any data directly from any register, but uses the AUTOSAR standard APIs provided by the MCAL Layer.
- When the channel is configured as Output, then the PPR register will
 reflect the Hardware pin level only when the Port Bi-Direction Control
 Register(PBDC) is enabled. Or else only the Port register value will be
 updated in the PPR register for the Output configured channels.
- DIO Driver at initialisation, does not initialise or write on any registers.
- Integrator should ensure that usage of DIO and PORT from two different OS tasks are avoided and PORT configured as high priority task.

4.2. Preconditions

Following preconditions have to be adhered by the user, for proper functioning of the DIO Driver Component:

- The Dio_Cfg.h and Dio_PBcfg.c files generated by the DIO Driver Component Code Generation Tool have to be linked along with DIO Driver Component source files.
- File Dio_PBcfg.c generated by DIO Driver Component Generation Tool can be compiled and linked independently.
- The application has to be rebuilt, if there is any change in the Dio_Cfg.h
 and Dio_PBcfg.c file generated by the DIO Driver Component Generation
 Tool.
- Dio_Ram.c and Dio_Ram.h are used only for Autosar release 4.0.3.
- The DIO Driver Component needs to be initialized before accepting any API requests. Dio_Init should be called to initialize DIO Driver Component.

Chapter 4 Forethoughts

 The authorization of the user for calling the software triggering of a hardware reset is not checked in the DIO Driver. This will be the responsibility of the upper layer.

- The user should ensure that DIO Driver Component API requests are invoked with correct input arguments.
- Input parameters are validated only when the static configuration parameter DioDevErrorDetect is enabled. Application should ensure that the right parameters are passed while invoking the APIs when DioDevErrorDetect is disabled.
- A mismatch in the version numbers of header and the source files will
 result in a compilation error. User should ensure that the correct versions
 of the header and the source files are used.
- User/Integrator should ensure that same Ports/Pins are configured for DIO Driver component.
- The DIO functions shall be called only after PORT Driver initialization, otherwise DIO functions will exhibit undefined behavior.
- Safety features related to Write-Verify are only available if 'DioWriteVerify' is enabled.

4.3. Data Consistency

To support the re-entrance services, the AUTOSAR DIO module will ensure the data consistency while accessing its own RAM storage or hardware registers. The DIO module will use SchM_Enter_Dio_<Exclusive Area> and SchM_Exit_Dio_<Exclusive Area> functions. The SchM_Enter_Dio_<Exclusive Area> function is called before the data needs to be protected and SchM_Exit_Dio_<Exclusive Area> function is called after the data is accessed.

The following exclusive area along with scheduler services is used to provide data integrity for shared resource:

DIO_REGISTER_PROTECTION

The functions SchM_Enter_Dio_<Exclusive Area> and SchM_Exit_Dio_<Exclusive Area> can be disabled by disabling the configuration parameter "DioCriticalSectionProtection".

Table 4-1 DIO Driver protected Resources List

API Name	Exclusive Area Type	Protected Resources
Dio_WritePort	DIO_REGISTER_PROTECTION	HW Registers: PMSR
Dio_WriteChannel	DIO_REGISTER_PROTECTION	HW Registers: PMSR
Dio_FlipChannel	DIO_REGISTER_PROTECTION	HW Registers: PMSR PNOT
Dio_WriteChannel	DIO_REGISTER_PROTECTION	HW Registers: PMSR

Forethoughts Chapter 4

Group		
Dio_MaskedWriteP ort	DIO_REGISTER_PROTECTION	HW Registers: PMSR

Note: The worst case critical section value is 0.850 microseconds measured for Dio_WriteChannelGroup API.

4.4. Deviation List

Table 4-2 Driver Deviation List of DIO module

SI. No.	Description AUTOSAR	Bugzilla
1.	The API Dio_MaskedWritePort which is available in R3.2.2 is also added to R4.0.3 release.	-
2.	In case of Multiple configuration sets used, configuring different short name for the containers 'DioPort', 'DioChannel' and 'DioChannelGroup' across the configuration set shall result in generation error.	-
3.	In case of Multiple configuration sets used, configuring different number of 'DioPort' or 'DioChannel' or 'DioChannelGroup' containers across the configuration set shall result in generation error.	-

4.5. User mode and supervisor mode

The below table specifies the APIs which can run in user mode, supervisor mode or both modes.

Table 4-3 User mode and Supervisor mode details

SI.No.	List of API'S	User Mode	Supervisor Mode	Known limitation in User mode
1.	Dio_Init	х	х	-
2.	Dio_ReadPort	х	х	-
3.	Dio_WritePort	х	х	-
4.	Dio_ReadChannel	х	х	-
5.	Dio_WriteChannel	х	х	-
6.	Dio_FlipChannel	х	х	-
7.	Dio_ReadChannelGroup	х	х	-
8.	Dio_WriteChannelGroup	х	х	-
9.	Dio_MaskedWritePort	х	х	-

Chapter 4 Forethoughts

10.	Dio_GetVersionInfo	х	х	-
	·			

Note: Implementation of Critical Section is not dependent on MCAL. Hence Critical Section is not considered to the entries for User mode in the above table.

Architecture Details Chapter 5

Chapter 5 Architecture Details

The overview of the AUTOSAR DIO software architecture is given in the following figure. The DIO Driver Component access the hardware features directly. The upper layers call the functionalities provided by DIO Driver Component:




Figure 5-1 DIO Driver Architecture

Chapter 5 Architecture Details

DIO Driver Component:

The following figure shows the various functionalities as offered by the DIO Driver.




Figure 5-2 DIO Driver Services

The DIO Driver Component is divided into the following sub modules based on the functionality required:

- · Port Read and Port Write
- · Channel Read and Channel Write
- · ChannelGroup Read and ChannelGroup Write

DIO Read Port

The levels of all channels of a DIO Port will be read. A bit value '0' indicates the individual channels of the Port to physical STD_LOW, a bit value '1' indicates the individual channels of the port to physical STD_HIGH. The level of all channels of Port are read simultaneously.

DIO Read Channel

The level of a single DIO Channel will be read as either STD_LOW or STD_HIGH.

DIO Read ChannelGroup

The levels of all channels of a DIO Channel Group will be read. A bit value '0' indicates the corresponding pin to physical STD_LOW, a bit value '1' indicates the corresponding channel to physical STD_HIGH.

Architecture Details Chapter 5

DIO Write Port

The levels of all channels of a Port will be set simultaneously without affecting the functionality of the input channels. A bit value '0' sets the corresponding channel to physical STD_LOW, a bit value '1' sets the corresponding channel to physical STD_HIGH.

DIO Write Channel

The level of a single DIO Channel is set STD_HIGH or STD_LOW.

DIO Write ChannelGroup

All adjoining subset of DIO channels of a port are set simultaneously. A bit value '0' sets the corresponding channel to physical STD_LOW, a bit value '1' sets the corresponding channel to physical STD_HIGH.

DIO Initialization

All the global variables of the DIO modules will be initialized.

DIO Flip Channel

The level of a single DIO channel will be set with compliment of current level that is, if current value is STD_HIGH then STD_LOW will be set and vice versa and then the level of a single DIO Channel will be read.

DIO GetVersionInfo

The Dio_GetVersionInfo function shall return the version information of this module. The version information includes module ID, Vendor ID and Vendor specific version numbers.

DIO MaskedWrite Port

The Dio_MaskedWritePort function shall set the specified value for the channels in the specified port if the corresponding bit in Mask is '1'.

Chapter 5 Architecture Details

Register Details Chapter 6

Chapter 6 Register Details

This section describes the register details of DIO Driver Component.

Table 6-1 Register Details

API Name	Registers	Config Parameter	Register Access R/W/RW	Macro/Variable
Dio_Init	-	-	-	-
Dio_ReadPort	PPRn	-	R	LddPortLevel
	JPPRn	-	R	LddPortLevel
Dio_WritePort	PSRn	-	R/W	Level
	JPSRn	-	R/W	Level
	PMSRn	-	R	LulPortModeLevel
	JPMSRn	-	R	LulPortModeLevel
Dio_ReadChannel	PPRn	DioChannelBitPosition	R	LddPortLevel
	JPPRn	DioChannelBitPosition	R	LddPortLevel
Dio_WriteChannel	PSRn	DioChannelBitPosition	R/W	LunPSRContent.ulLongWord
	JPSRn	DioChannelBitPosition	R/W	LunPSRContent.ulLongWord
	PMSRn	-	R	LulPortModeLevel
	JPMSRn	-	R	LulPortModeLevel
Dio_FlipChannel	PNOTn	DioChannelBitPosition	W	-
	JPNOTn	DioChannelBitPosition	W	-
	PPRn	DioChannelBitPosition	R	LddPortLevel
	JPPRn	DioChannelBitPosition	R	LddPortLevel
	PMSRn	-	R	LulPortModeLevel
	JPMSRn	-	R	LulPortModeLevel
Dio_ReadChannelGroup	PPRn	DioPortMask and DioPortOffset	R	LddPortLevel
	JPPRn	DioPortMask and DioPortOffset	R	LddPortLevel
Dio_WriteChannelGroup	PSRn	DioPortMask and DioPortOffset	R/W	LunPSRContent.ulLongWord
	JPSRn	DioPortMask and DioPortOffset	R/W	LunPSRContent.ulLongWord
	PMSRn	-	R	LulPortModeLevel
	JPMSRn	-	R	LulPortModeLevel
Dio_GetVersionInfo	-	-	-	-
Dio_MaskedWritePort	PSRn	-	R/W	-
	JPSRn	-	R/W	-
	PMSRn	-	R	LulPortModeLevel
	JPMSRn	-	R	LulPortModeLevel

Chapter 6 Register Details

Chapter 7 Interaction between the User and DIO Driver Component

The details of the services supported by the DIO Driver Component to the upper layers users and the mapping of the channels to the hardware units is provided in the following sections:

7.1. Services Provided By DIO Driver Component To The User

The DIO Driver Component provides the following functionalities to the upper layers or users:

- · To initialize the DIO module.
- · To read the physical level value from DIO Port.
- · To write specified value into given DIO Port.
- To read physical level value from DIO Channel.
- To write a specified value into the given DIO Channel.
- · To read physical level value from DIO ChannelGroup.
- To write specified value into DIO ChannelGroup.
- To read the DIO Driver Component version information.
- To write specified value with a specified mask into given DIO Port.
- To flip the level of a channel and return the level of the channel after flip.

Chapter 8 DIO Driver Component Header and Source File Description

This section explains the DIO Driver Component's source and header files. These files have to be included in the project application while integrating with other modules.

The C header file generated by DIO Driver Component Code Generation Tool:

- Dio_Cfg.h
- Dio_Cbk.h

The C source file generated by DIO Driver Component Code Generation

Tool:

• Dio_PBcfg.c

The DIO Driver Component C header files:

- Dio.h
- · Dio_Debug.h
- Dio_PBTypes.h
- Dio_Ram.h
- Dio_Version.h
- Dio_RegWrite.h

The DIO Driver Component C source files:

- Dio.c
- Dio_Ram.c
- Dio_Version.c

The Stub C header files:

- Compiler.h
- Compiler_Cfg.h
- MemMap.h
- Platform_Types.h
- Det.h
- · Rte.h
- SchM_Dio.h

- Dem.h
- Std_Types.h

The description of the DIO Driver Component files is provided in the table below:

Table 8-1 Description of the DIO Driver Component Files

File	Details	
Dio_Cfg.h	This file is generated by the DIO Driver Component Code Generation Tool for DIO Driver Component pre-compile time parameters. This file contains macro definitions for the configuration elements. The macros and the parameters generated will vary with respect to the configuration in the input ARXML file.	
Dio_Cbk.h	This file contains declarations of notification functions to be used by the application. The notification function name can be configured.	
Dio_PBcfg.c	This file contains post-build configuration data. The structures related to DIO Initialization are provided in this file. Data structures will vary with respect to parameters configured.	
Dio.h	This file provides extern declarations for all the DIO Driver Component APIs. This file provides service Ids of APIs, DET Error codes and Global Data Types for DIO Driver component. This header file shall be included in other modules to use the features of DIO Driver Component.	
Dio_Debug.h	This file provides Provision of global variables for debugging purpose.	
Dio_RegWrite.h	This file is to have macro definitions for the registers write and verification.	
Dio_PBTypes.h	This file contains the macros used internally by the DIO Driver Component code and the structure declarations related to hardware unit registers, HARDWARE unit, Channel configuration, Group configuration, Group RAM data and HARDWARE unit RAM data.	
Dio_Ram.h	This file contains the extern declarations for the global variables that are defined in Dio_Ram.c file and the version information of the file.	
Dio_Version.h	This file contains the macros of AUTOSAR version numbers of all modules that are interfaced to DIO.	
Dio.c	This file contains the implementation of all DIO Driver Component APIs.	
Dio_Version.c	This file contains the code for checking version of all modules that are interfaced to DIO.	
Dio_Ram.c	This file contains the global variables used by DIO Driver Component.	
Compiler.h	Provides compiler specific (non-ANSI) keywords. All mappings of keywords, which are not standardized, and/or compiler specific are placed and organized in this compiler specific header.	
Compiler_Cfg.h	This file contains the memory and pointer classes.	
MemMap.h	This file allows to map variables, constants and code of modules to individual memory sections. Memory mapping can be modified as per ECU specific needs.	
Platform_Types.h	This file provides provision for defining platform and compiler dependent types.	
Det.h	This file is a stub for DET Component.	
Rte.h	This file is a stub for Rte Component.	
Std_Types.h	This file is a stub file which contains the standard type definitions.	
SchM_Dio.h	This file provide a stub for SchM component.	
Dem.h	This file provides a stub for Dem component.	

Generation Tool Guide Chapter 9

Chapter 9 Generation Tool Guide

For more information on the Dio Driver Component Generation Tool, please refer "R20UT3709EJ0101-AUTOSAR.pdf" document.

Chapter 9 Generation Tool Guide

Chapter 10 Application Programming Interface

This section explains the Data types and APIs provided by the DIO Driver Component to the Upper layers.

10.1. Imported Types

This section explains the Data types imported by the DIO Driver Component and lists its dependency on other modules.

10.1.1. Standard Types

In this section all types included from the Std_Types.h are listed: Std_VersionInfoType

10.1.2. Other Module Types

DIO Driver Component module does not depend on other modules. Hence no types from other modules are imported.

10.2. Type Defintions

This section explains the type definitions of DIO Driver Component according to AUTOSAR Specification.

Refer "AUTOSAR_SWS_DIODriver.pdf" for more type definitions

10.2.1. Dio_ChannelType

Name:	Dio_ChannelType	
Type:	uint8	
Range:	0 to 255	
Description:	Type definition for Dio_ChannelType used by Dio_ReadChannel and Dio_WriteChannel	

10.2.2. Dio_PortType

Name:	Dio_PortType
Type:	uint8
Range:	0 to 255
Description:	Type definition for Dio_PortType used by Dio_ReadPort and Dio_WritePort.

10.2.3. Dio_PortLevelType

Name:	Dio_PortLevelType
Type:	uint16
Range:	0 to 65535
Description:	Type definition for Dio_PortLevelType used by Dio_ReadPort, Dio_WritePort, Dio_ReadChannelGroup and Dio_WriteChannelGroup.

10.2.4. Dio_ConfigType

Name:	Dio_ConfigType
Type:	Structure
Range:	Implementation specific.
Description:	This structure contains all post-build configurable parameters of the DIO driver. A pointer to this structure is passed to the DIO driver initialization function for configuration.

10.3. Function Definitions

Table10-1 DIO Driver Component's API list.

SI no	API's of R4.0.3
4	B: 1.5
1.	Dio_Init
2.	Dio_ReadPort
3.	Dio_WritePort
4.	Dio_ReadChannel
5.	Dio_WriteChannel
6.	Dio_FlipChannel
7.	Dio_ReadChannelGroup
8.	Dio_WriteChannelGroup
9.	Dio_MaskedWritePort
10.	Dio_GetVersionInfo

10.3.1. **Dio_Init**

Name:	Dio_Init			
Prototype:	FUNC (void, DIO_PUBLIC_CODE) Dio_Init (P2CONST(Dio_ConfigType, DIO_VAR, DIO_APPL_CONST) ConfigPtr)			
Service ID:	0x10			
Sync/Async:	Synchronous			
Reentrancy:	Non-Reentrant			
	Type Parameter Value/Range			
Parameters In:	Dio_ConfigType	ConfigPtr	NA	
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
	Туре	Possible Return	Values	
Return Value:	None None			
Description:	Initializes the Dio module.			
Configuration Dependency:	None			
Preconditions:	None			

10.3.2. Dio_ReadPort

Name:	Dio_ReadPort			
Prototype:	FUNC(Dio_PortLevelType, DIO_PUBLIC_CODE) Dio_ReadPort(Dio_PortType PortId)			
Service ID:	0x02			
Sync/Async:	Synchronous			
Reentrancy:	Reentrant			
	Type Parameter Value/Range			
Parameters In:	Dio_PortType	PortId	0 255	
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
_	Туре	Possible Return	Values	
Return Value:	Dio_PortLevelType	0 to 65535		
Description:	This service returns the level of all channels of given port.			
Configuration Dependency:	None			
Preconditions:	DIO Driver must be initiali	zed		

10.3.3. Dio_WritePort

Name:	Dio_WritePort			
Prototype:	FUNC(void, DIO_PUBLIC_CODE) Dio_WritePort (Dio_PortType PortId, Dio_PortLevelType Level)			
Service ID:	0x03			
Sync/Async:	Synchronous			
Reentrancy:	Reentrant			
_	Туре	Parameter	Value/Range	
Parameters In:	Dio_PortType	Portld	0255	
	Dio_PortLevelType	Level	0x00 / 0x01	
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
	Туре	Possible Return	n Values	
Return Value:	None	None None		
Description:	This service writes the specified level to all the channels in given Port.			
Configuration Dependency:	None			
Preconditions:	DIO Driver must be initia	lized.		

10.3.4. Dio_ReadChannel

Name:	Dio_ReadChannel	Dio_ReadChannel		
Prototype:	FUNC(Dio_LevelType, DIO_PUBLIC_CODE) Dio_ReadChannel(Dio_ChannelType ChannelId)			
Service ID:	0x00			
Sync/Async:	Synchronous			
Reentrancy:	Reentrant			
	Type Parameter Value/Range			
Parameters In:	Dio_ChannelType ChannelId 0 255			
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
	Туре	Possible Retu	rn Values	
Return Value:	Dio_LevelType 0x00 / 0x01			
Description:	This service returns the value of the specified DIO channel.			
Configuration Dependency:	None			
Preconditions:	This service returns the	value of the spec	ified DIO channel.	

10.3.5. Dio_WriteChannel

Name:	Die WriteChannel			
Name.	Dio_WriteChannel			
	FUNC(void, DIO_PUBLIC_CODE) Dio_WriteChannel			
Prototype:	(Dio_ChannelType ChannelId, Dio_LevelType Level)			
Service ID:	0x01			
Sync/Async:	Synchronous			
Reentrancy:	Reentrant			
	Туре	Parameter	Value/Range	
Parameters In:	Dio_ChannelType	Channel Id	0255	
	Dio_PortLevelType Level 0x00 / 0x01			
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
	Туре	Possible Return	Values	
Return Value:	None	ne None		
Description:	This service writes the value of the level into specified channel of given port.			
Configuration Dependency:	None			
Preconditions:	DIO Driver must be initial	ized.		

10.3.6. Dio_ReadChannelGroup

Name:	Dio_ReadChannelGroup			
Prototype:	FUNC(Dio_PortLevelType, DIO_PUBLIC_CODE) Dio_ReadChannelGroup (P2CONST(Dio_ChannelGroupType, DIO_VAR, DIO_CONFIG_CONST) ChannelGroupIdPtr)			
Service ID:	0x04			
Sync/Async:	Synchronous			
Reentrancy:	Reentrant			
	Туре	Parameter Value/Range ype ChannelGroupIdPtr NA		
Parameters In:	Dio_ChannelGroupType			
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
Return Value:	Туре	Possible Return Value	es	
	Dio_PortLevelType 0 to 65535			
Description:	This Service reads a subset of the adjoining bits of a port.			
Configuration Dependency:	None			
Preconditions:	DIO Driver must be initiali	zed.		

10.3.7. Dio_WriteChannelGroup

Name:	Dio_WriteChannelGroup			
Prototype:	FUNC(void, DIO_PUBLIC_CODE) Dio_WriteChannelGroup (P2CONST(Dio_ChannelGroupType, DIO_VAR, DIO_CONFIG_CONST) ChannelGroupIdPtr, Dio_PortLevelType Level)			
Service ID:	0x05			
Sync/Async:	Synchronous			
Reentrancy:	Reentrant			
	Type Parameter Value/Range			
Parameters In:	Dio_ChannelGroupType	ChannelGroupIdPtr	NA	
	Dio_PortLevelType Level 0x00 / 0x01			
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
	Туре	Possible Return Value	es	
Return Value:	None None			
Description:	Service to set a subset of the adjoining bits of a port to a specified level.			
Configuration Dependency:	None			
Preconditions:	DIO Driver must be initiali	zed.		

10.3.8. Dio_MaskedWritePort

Name:	Dio_MaskedWritePort			
Prototype:	FUNC(void, DIO_PUBLIC_CODE) Dio_MaskedWritePort (Dio_PortType PortId, Dio_PortLevelType Level,Dio_PortLevelType Mask)			
Service ID:	0x13			
Sync/Async:	Synchronous			
Reentrancy:	Reentrant			
_	Туре	Parameter	Value/Range	
Parameters In:	Dio_PortType	PortId	0 255	
	Dio_PortLevelType Level 0x00 / 0x01			
	Dio_PortLevelType	Mask	0 65535	
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
_	Туре	Possible Return	n Values	
Return Value:	None	None		
Description:	Service to set the value of a given port with required mask.			
Configuration Dependency:	Parameter DioMaskedWritePortApi should be configured as TRUE			
Preconditions:	DIO Driver must be initial	zed.		

10.3.9. Dio_FlipChannel

Name:	Dio_FlipChannel			
Prototype:	FUNC(Dio_LevelType, DIO_PUBLIC_CODE) Dio_FlipChannel(Dio_ChannelType ChannelId)			
Service ID:	0x11			
Sync/Async:	Synchronous			
Reentrancy:	Reentrant			
_	Type Parameter Value/Range			
Parameters In:	Dio_ChannelType	Channel Id	0255	
Parameters InOut:	None	NA	NA	
Parameters out:	None	NA	NA	
	Туре	Possible Retu	rn Values	
Return Value:	Dio_LevelType	evelType 0x00 / 0x01		
Description:	Service to flip (change from 1 to 0 or from 0 to 1) the level of a channel and return the level of the channel after flip.			
Configuration Dependency:	Parameter DioFlipChan	Parameter DioFlipChannelApi should be configured as TRUE		

Preconditions:	DIO Driver must be initialized.

10.3.10. Dio_GetVersionInfo

Name:	Dio_GetVersionInfo				
Prototype:	FUNC(void, DIO_PUBLIC_CODE) Dio_GetVersionInfo (P2VAR(Std_VersionInfoType, AUTOMATIC, DIO_APPL_DATA)versioninfo)				
Service ID:	0x12				
Sync/Async:	Synchronous				
Reentrancy:	Reentrant				
	Type Parameter Value/Range				
Parameters In:	None	one None NA			
Parameters InOut:	None	NA	NA		
Parameters out:	Std_VersionInfoType	Versioninfo	NA		
	Туре	Possible Return	Values		
Return Value:	None None				
Description:	Service to get the version information of dio module.				
Configuration Dependency:	Parameter DioVersionInfoApi should be configured as TRUE				
Preconditions:	DIO Driver must be initial	ized.			

Chapter 11 Development and Production Errors

In this section the development errors that are reported by the DIO Driver Component are tabulated. The development errors will be reported only when the pre compiler option DIO_DEV_ERROR_DETECT is enabled in the configuration. The DIO Driver Component does not support any production errors.

11.1. DIO Driver Component Development Errors

The following contains the DET errors that are reported by DIO Driver Component. These errors are reported to Development Error Tracer Module when the DIO Driver Component APIs are invoked with wrong input parameters or without initialization of the driver.

Table11-1 DET Errors of DIO Driver Component

SI. No.	1
Error Code	DIO_E_PARAM_INVALID_CHANNEL_ID
Related API(s)	Dio_ReadChannel , Dio_WriteChannel and Dio_FlipChannel
Source of Error	When the above mentioned APIs are invoked with invalid Channel ID
SI. No.	2
Error Code	DIO_E_PARAM_CONFIG
Related API(s)	Dio_Init
Source of Error	When the above mentioned API is invoked with NULL parameter.
SI. No.	3
Error Code	DIO_E_PARAM_INVALID_PORT_ID
Related API(s)	Dio_ReadPort, Dio_WritePort , Dio_WriteChannel, Dio_FlipChannel, Dio_WriteChannelGroup and Dio_MaskedWritePort
Source of Error	When the above mentioned APIs are invoked with invalid Port ID
SI. No.	4
Error Code	DIO_E_PARAM_INVALID_GROUP
Related API(s)	Dio_ReadChannelGroup and Dio_WriteChannelGroup
Source of Error	When the above mentioned APIs are invoked with invalid ChannelGroup ID
SI. No.	5
Error Code	DIO_E_INVALID_DATABASE
Related API(s)	Dio_Init
Source of Error	When the above mentioned API is called without a database or invalid database

SI. No.	6
Error Code	DIO_E_UNINIT
Related API(s)	Dio_ReadChannel, Dio_WriteChannel, Dio_ReadPort, Dio_WritePort, Dio_ReadChannelGroup, Dio_WriteChannelGroup and Dio_FlipChannel, Dio_MaskedWritePort
Source of Error	When the above mentioned APIs are invoked without module initialization.
SI. No.	7
Error Code	DIO_E_PARAM_POINTER
Related API(s)	Dio_ReadChannelGroup , Dio_WriteChannelGroup and Dio_GetVersionInfo
Source of Error	When the above mentioned APIs are invoked with NULL pointer

11.2. DIO Driver Component Production Errors

In this section the DEM errors identified in the DIO Driver component are listed. DIO Driver component reports these errors to DEM by invoking Dem_ReportErrorStatus API. This API is invoked, when the processing of the given API request fails.

Table11-2 DEM Errors of DIO Driver Component

SI. No.	1
Error Code	DIO_E_REG_WRITE_VERIFY
Related API(s)	Dio_WritePort, Dio_WriteChannel, Dio_FlipChannel, Dio_WriteChannelGroup, Dio_MaskedWritePort
Source of Error	When register write-verify fails.

Chapter 12 Memory Organization

Following picture depicts a typical memory organization, which must be met for proper functioning of DIO Driver Component software.




Figure 12-1 DIO Driver Component Memory Organization

DIO_PUBLIC_CODE_ROM (X1): API(s) of DIO Driver Component, which can be located in code memory.

DIO_CFG_DATA_UNSPECIFIED (X2): This section consists of DIO Driver Component constant configuration structures. This can be located in code memory.

RAM Section (Y1, and Y2):

NO_INIT_RAM_UNSPECIFIED (Y1): This section consists of the global RAM pointer variables that are used internally by DIO Driver Component. This can be located in data memory.

RAM_1BIT (Y2): This section consists of the global RAM variables of 1-bit size that are used internally by DIO Driver Component. This can be located in data memory.

NO_INIT_RAM_16BIT (Y3): This section consists of the global RAM variables of 16-bit size that are used internally by DIO Driver Component and other software components. The specific sections of respective software components will be merged into this RAM section accordingly. This can be located in data memory.

Notes:

- X1, Y1, and Y2 pertain to only DIO Driver Component and do not include memory occupied by Dio_PBcfg.c files generated by DIO Driver Component Generation Tool.
- User must ensure that none of the memory areas overlap with each other. Even 'debug' information should not overlap.

Chapter 13 P1M Specific Information

P1M supports following devices:

- R7F701304
- R7F701305
- R7F701310
- R7F701311
- R7F701312
- R7F701313
- R7F701314
- R7F701315
- R7F701318
- R7F701319
- R7F701320
- R7F701321
- R7F701322
- R7F701323

13.1. Interaction between the User and DIO Driver Component

13.1.1. Translation Header File

The P1x_translation.h file supports following devices:

- R7F701304
- R7F701305
- R7F701310
- R7F701311
- R7F701312
- R7F701313
- R7F701314
- R7F701315
- R7F701318
- R7F701319
- R7F701320
- R7F701321
- R7F701322
- R7F701323

13.1.2. Parameter Definition File

Parameter definition files support information for P1M

Table13-1 PDF information for P1M

PDF Files	Devices Supported	
R403_DIO_P1M_04_05_12_13_20_21. arxml	701304, 701305, 701312, 701313, 701320, 701321	
R403_DIO_P1M_10_11_14_15_18_19 _22_23.arxml	701310, 701311, 701314, 701315, 701318, 701319, 701322, 701323	

13.2. Sample Application

13.2.1 Sample Application Structure

The Sample Application is provided as reference to the user to understand the method in which the DIO APIs can be invoked from the application.




Figure 13-1 Overview of DIO Driver Sample Application

The Sample Application of the P1M is available in the path X1X/P1x/modules/dio/sample_application

The Sample Application consists of the following folder structure X1X/P1x/modules/dio/definition/<Subvariant>/R403_DIO_P1M_04_05_12_13_20_21.arxml X1X/P1x/modules/dio/definition/<Subvariant>/R403_DIO_P1M_10_11_14_15_18_19_22_23.arxml

X1X/P1x/modules/dio/sample_application/<Subvariant> /<AUTOSAR_version> /src/Dio_PBcfg.c /inc/Dio_Cfg.h /inc/Dio_Cbk.h

/config/App_DIO_P1M_701304_Sample.arxml
/config/App_DIO_P1M_701305_Sample.arxml
/config/App_DIO_P1M_701310_Sample.arxml
/config/App_DIO_P1M_701311_Sample.arxml
/config/App_DIO_P1M_701312_Sample.arxml
/config/App_DIO_P1M_701313_Sample.arxml
/config/App_DIO_P1M_701314_Sample.arxml
/config/App_DIO_P1M_701315_Sample.arxml
/config/App_DIO_P1M_701318_Sample.arxml
/config/App_DIO_P1M_701319_Sample.arxml
/config/App_DIO_P1M_701320_Sample.arxml
/config/App_DIO_P1M_701321_Sample.arxml
/config/App_DIO_P1M_701322_Sample.arxml
/config/App_DIO_P1M_701322_Sample.arxml
/config/App_DIO_P1M_701323_Sample.arxml

In the Sample Application all the DIO APIs are invoked in the following sequence:

- The API Dio_GetVersionInfo is invoked to get the version of the DIO
 Driver module with a variable of Std_VersionInfoType, after the call of
 this API the passed parameter will get updated with the DIO Driver
 version details.
- The API Dio_Init is invoked with a valid database address for the proper initialization of the DIO Driver, all the DIO Driver control registers and RAM variables will get initialized after this API is called.
- The API Dio_WriteChannel is invoked to set the required level of a

- particular channel. It sets the output level of the channel if that particular channel is configured in output mode. If channel is configured for input mode, Dio WriteChannel has no effect.
- The API Dio_ReadChannel reads the actual physical level of the required channel. The level read for the input channel is actual physical level of that channel if input buffer for that channel is enabled. The level read for the output channel is actual physical level of that channel if bidirectional control for that channel is enabled.
- The API Dio_WritePort is invoked to simultaneously set the required levels to all channels of a port. It sets the output level of the channels which are configured in output mode, for the channels which are configured in input mode, Dio_WritePort has no effect.
- The API Dio_ReadPort reads the actual physical level of all the port pins of a required port. The level read for the input port pin is actual physical level of that port pin if input buffer for that port pin is enabled.
 The level read for the output port pin is actual physical level of that port pin if bidirectional control for that port pin is enabled.
- The API Dio_WriteChannelGroup is invoked to simultaneously set the required levels to group of channels of a port. It sets the output level of the channels which are configured in output mode, for the channels which are configured in input mode, Dio_WriteChannelGroup has no effect.
- The API Dio_ReadChannelGroup reads the actual physical level of channel group of a required port. The level read for the input channel group is actual physical level of that channel group if input buffer for that channel group is enabled. The level read for the output channel group is actual physical level of that channel group if bidirectional control for that channel group is enabled.
- The API Dio_MaskedWritePort provides service to set value of given port
 with required mask.The Dio_MaskedWritePort function shall set the
 specified value for the channel in specified port if the corresponding bit in
 mask is '1'.
- The API Dio_FlipChannel reads the level of the channel and invert it, then write the inverted level to the channel if the channel is configured as output channel and the function shall have no influence on the physical output if the channel is configured as input channel.

13.2.2 Building Sample Application

13.2.2.1 Configuration Example

This section contains the typical configuration which is used for measuring RAM/ROM consumption, stack depth and throughput details.

Configuration Details:

Name of the configuration file:

App_DIO_<SubVariant>_<Device_Name>_Sample.arxml

13.2.2.2 Debugging the Sample Application

Remark

GNU Make utility version 3.81 or above must be installed and available in the path as defined by the environment user variable "GNUMAKE" to complete the build process using the delivered sample files.

 Open a Command window and change the current working directory to "make" directory present as mentioned in below path: "X1X\P1x\common_family\make\<Compiler>"

Now execute batch file SampleApp.bat with following parameters:

SampleApp.bat dio 4.0.3 < Device_name >

<Device_name> can be 701304, 701305, 701310, 701311, 701312, 701313, 701314, 701315, 701318, 701319, 701320, 701321, 701322 and 701323.

After this, the tool output files will be generated with the configuration as mentioned in App_DIO_P1M_<Device_name>_Sample.arxml file available in the path:

- "X1X\P1x\modules\dio\sample_application\<SubVariant>\<AUTOSAR_version>\config"
- After this, all the object files, map file and the executable file Sample.out
 will be available in the output folder
 ("X1X\P1x\modules\dio\sample_application\<SubVariant>\obj\<Compiler>"
 in this case).
- The executable can be loaded into the debugger and the sample application can be executed.

Remark Executable files with '*.out' extension can be downloaded into the target hardware with the help of Green Hills debugger.

- If any configuration changes (only post-build) are made to the ECU Configuration Description files
- "X1X\P1x\modules\dio\sample_application\< SubVariant > \<AUTOSAR_version>config \ App_DIO_P1M_701318_Sample.arxml"

The database alone can be generated by using the following commands.

```
make –f App_DIO_P1M_Sample.mak generate_dio_config make –f App_DIO_P1M_Sample.mak App_Dio_P1M_Sample.s37
```

After this, a flashable Motorola S-Record file App_Dio_P1M_Sample.s37 is available in the output folder.

13.3. Memory and Throughput

13.3.1. ROM/RAM Usage

The details of memory usage for the typical configuration provided in Section 13.2.2.1 *Configuration Example* are provided in this section.

Table13-2 ROM/RAM Details with DET

SI. No.	ROM/ RAM	Segment Name	Size in bytes for 144 pin device R7F701318
1.	ROM	DIO_PUBLIC_CODE_ROM	1530
		DIO_PRIVATE_CODE_ROM	0
		CONST_ROM_UNSPECIFIED	0
		DIO_CFG_DATA_UNSPECIFIED	72
2.	RAM	NO_INIT_RAM_16BIT	2
		NO_INIT_RAM_UNSPECIFIED	8
		DIO_CFG_RAM_UNSPECIFIED	0

The details of memory usage for the typical configuration, with DET enabled and all other configurations as provided in 13.2.2.1 *Configuration Example* are provided in this section.

Table13-3 ROM/RAM Details without DET

SI. No.	ROM/ RAM	Segment Name	Size in bytes for 144 pin device R7F701318
1.	ROM	DIO_PUBLIC_CODE_ROM	836
		DIO_PRIVATE_CODE_ROM	0
		CONST_ROM_UNSPECIFIED	0
		DIO_CFG_DATA_UNSPECIFIED	72
2.	RAM	NO_INIT_RAM_16BIT	2
		NO_INIT_RAM_UNSPECIFIED	8
		DIO_CFG_RAM_UNSPECIFIED	0

13.3.2. Stack Depth

The worst-case stack depth for DIO Driver Component for the typical Configuration provided in Section 13.2.2.1 is 24 bytes.

13.3.3. Throughput Details

The throughput details of the APIs for the configuration mentioned in the Section13.2.2.1 Configuration Example.

The clock frequency used to measure the throughput is 80 MHz for all APIs.

Table13-4 Throughput Details of the APIs

SI. No.	API Name	Throughput in microseconds for R7F701318	Remarks
1.	Dio_Init	0.3	-
2.	Dio_WriteChannel	1.275	-
3.	Dio_ReadChannel	0.475	-
4.	Dio_WritePort	1.112	-
5.	Dio_ReadPort	0.325	-
6.	Dio_WriteChannelGroup	1.287	-
7.	Dio_ReadChannelGroup	0.5	-
8.	Dio_MaskedWritePort	1.1	-
9.	Dio_FlipChannel	1.375	-
10.	Dio_GetVersionInfo	0.137	-

Release Details Chapter 14

Chapter 14 Release Details

DIO Driver Software

Version: 1.0.12

Chapter 14 Release Details

Revision History

SI.No.	Description	Version	Date
1.	Initial Version	1.0.0	30-Sep-2013
2	Updated for 100 pins and 144 pins device for P1x E4.02	1.0.1	27-Jan-2014
3	Following change is made: In page no 40, Header is changed. In section 13.3.2.1, configuration file mentioned changed. In page no 54, Header is added.	1.0.2	13-Mar-2014
4.	 Following change is made: In section 13.4 RAM/ROM details and throughput details are updated. Section 13.1.2 is added. Section 13.2 is updated for compile and Linker and Assembler options. 	1.0.3	25-Aug-2014
5.	Following changes are made: Table 11-1 is updated. Repeated DIO_CFG_DBTOC_UNSPECIFIED is removed from RAM section from table 13-5 and from table 13-6. DIO_E_PARAM_POINTER is removed from DET Error codes.	1.0.4	04-Sep-2014
6.	User manual is updated as per Template. Dio_MaskedWritePort information is provided in section 5 and section 7. Throughput Details are updated in section 13.4.3	1.0.5	18-Nov-2014
7.	 Following changes are made: Chapter 2 reference documents section is updated. Chapter 3 section 3.1.1 is updated for new devices. Chapter 4 section 4.1 General is updated and a note is added regarding interrupt vector (.c) file Chapter 4 section 4.4 Deviation list is updated. Chapter 13 Section for compiler, linker, and assembler details is removed. Chapter 13 13.1.1 Translation header files section is updated as per new devices. 13.1.2 PDF section is updated as per new devices. 13.2.1 Sample application structure is updated for new devices 13.2.2 Building sample application section is updated 13.3 Memory and throughput details are updated for 144 pin devices. 	1.0.6	27-May-2015
8.	Following changes are made, 1. In section 13.2, the description details for the APIs are updated. 2. In Chapter 14,DIO Driver Software version is updated 3. In Chapter 4, section General is updated. 4. Chapter 2 is updated for related documents. 5. Chapter 3 is updated for RUCG details. 6. Chapter 9 is updated for R-Number version of TUM. 7. Chapter 12 'Memory Organization' has been updated to remove the sections DIO_CFG_DBTOC_UNSPECIFIED and RAM_1BIT and added NOINIT_RAM_16BIT. 8. Chapter 13.3 'Memory and Throughput' is updated. 9. Section 4.3 Data Consistency is updated for exclusive areas.	1.0.7	28-Mar-2016

SI.No.	Description	Version	Date
9	 Following changes are made, 1. Updated section 4.4 Deviation list 2. Updated section 13.3. Memory and throughput details. 3. Added a 'Note' below the table 'Supervisor mode and User mode details'. 4. Updated section 13.2, removed reference to .one and .html files 5. Updated Chapter 6 'Register Details'. 6. Updated section 4.3 Data consistency by adding Table 4-1 Dio driver protected resources list. 7. R Number updated. 8. Updated Chapter 14 'Release Details'. 9.Updated Chapter 12 'Memory Organization'. 10.Chapter 8 is updated for Dio_RegWrite.h in C Header files and Std_Types.h added to Stub files. 11.Clock frequency mentioned in section 13.3.3 is changed to 80Mhz. 	1.0.8	04-Aug-2016
10	Following changes are made, 1. Updated Chapter 6 'Register Details'. 2. Updated section 13.3 Memory and Throughput. 3. Updated section 4.2 Preconditions. 4. Updated section 3.1.1 Folder Structure.	1.0.9	21-Oct-2016
11	Following changes are made: 1. Section 10.3 Function Definitions updated. 2. Updated Chapter 11 Development and Production Errors. 3. Abbreviations and Acronyms updated. 4. Chapter 2 'Reference section' updated. 5. R Number updated. 6. Updated Driver Version Details in Chapter 14 'Release Details'. 7. Updated section 13.3 'Memory and Throughput'. 8. Updated chapter 4 'Forethoughts'. 9. Updated notice and copyright information. 10. Modified Figure 5-2 in chapter 5.	1.0.10	16-Feb-2017

AUTOSAR MCAL R4.0.3 User's Manual DIO Driver Component Ver.1.0.10 Embedded User's Manual

Publication Date: Rev.1.01, February 16, 2017

Published by: Renesas Electronics Corporation



SALES OFFICES

Renesas Electronics Corporation

http://www.renesas.com

Refer to "http://www.renesas.com/" for the latest and detailed information

Renesas Electronics America Inc.
2801 Sout Boulevard Santa Clara, CA 95050-2549, U.S.A.
Tel: +1-409-588-6000, Fax: +1-408-588-6130
Renesas Electronics Canada Limited
9251 Yonge Street, Suite 8309 Richmond Hill, Ontario Canada L4C 9T3
Tel: +1-905-237-2004

Reneasa Electronics Europe Limited
Dukes Meadow, Millboard Road, Bourne End, Buckinghamshire, SL8 5FH, U.K
Tel: +44-1628-585-100, Fax: +44-1628-585-900

1ei: 144-1625-585-10U, Fax: 1443-1625-585-90U

Reneass Electronics Europe GmbH

Arcadiastrasse 10, 40472 Düsseldorf, Germany

1ei: 149-211-6503-0, Fax: 149-211-6503-1327

Renesse Electronics (China) Co., Ltd.

Room 1709, Quantum Plaza, No.27 ZhiChunLu Haidian District, Beijing 100191, P.R.China

Tei: 148-10-6225-1155, Fax: 148-10-6225-7679

Reneasa Electronics (Shanghal) Co., Ltd.
Unit 301, Tower A, Central Towers, 555 Langao Road, Putuo District, Shanghai, P. R. China 200333
Tel: 486-21-2226-0886, Fax. 486-21-2226-0999

Tel: +86-21-2226-0888, Fax: +86-21-2226-0999

Renesas Electronics Hong Kong Limited
Unit 1601-1611, 1617-, Tower 2, Grand Century Place, 193 Prince Edward Road West, Mongkok, Kowloon, Hong Kong
Tel: +852-2265-6688, Fax: +852 2886-9022

Renesas Electronics Taiwan Co., Ltd.
137- No. 363, Fu Shing North Road, Taipei 10543, Taiwan
Tel: +886-2-1875-9600, Fax: +886-2-1875-9670

Renesas Electronics Singapore Pte. Ltd.
30 Bendemeer Road, Unit #06-02 hyllux Innovation Centre, Singapore 339949
Tel: +655-6213-0200, Fax: +65-6213-0300

Reneasa Electronics Malaysia Sdn.Bhd.
Unit 1207, Block B, Menara Amoorp, Amoorp Trade Centre, No. 18, Jln Persiaran Barat, 46050 Petaling Jaya, Selangor Darul Ehsan, Malaysia
Tei: +60-3-7955-9390, Fax: +60-3-7955-9510

Renesas Electronics India Pvt. Ltd.
No.777C, 100 Feet Road, HAL II Stage, Indiranagar, Bangalore, India Tel: +91-80-67208700, Fax: +91-80-67208777

Renesas Electronics Korea Co., Ltd. 12F., 234 Teheran-ro, Gangnam-Gu, Seoul, 135-080, Korea Tel: +82-2-558-3737, Fax: +82-2-558-5141

AUTOSAR MCAL R4.0.3 User's Manual

